

CATERING VEHICLE/TRAILER CHECK

Certificate Number:

DETAILS OF THE INSTALLATION ADDRESS	DETAILS OF THE CLIENT ADDRESS
Installation Address: Postcode: 	Client Address: The Rather Good Spud Co 53 Hornby Rd Brighton And Hove Postcode: BN2 3JH

VEHICLE DETAILS			
Type:	Trailer	Reg/Chassis No:	x
Is a fire extinguisher available		YES	
Is the cylinder housing adequate		YES	
Is a fire blanket available		YES	
Is LPG safety information displayed		YES	
Is there a safety ticket displayed		YES	

APPLIANCE DETAILS							
	Appliance Type	Make	Model	Serial No	Appliance Secured	Isolation Value Fitted	Flue Type
1	Potato oven	N/A	N/A	N/A	Yes	Yes	FL
2	Bay marie	N/A	N/A	N/A	Yes	Yes	FL
3	Bay marie	N/A	N/A	N/A	Yes	Yes	FL
4	Griddle	N/A	N/A	N/A	Yes	Yes	FL
5	Water Heater	N/A	N/A	N/A	Yes	Yes	FL

INSPECTION DETAILS								
	Operating Pressure in mbar or heat input in kW	Safety Devices(s) Correct Operation	Ventilation Provision Satisfactory	Visual Condition of Flue and Termination Satisfactory	Flue Performance Test	Appliance Serviced	Spillage Check	Appliance Safe To Use
1	9	Yes	Yes	N/A	N/A	Yes	N/A	Yes
2	5.8	Yes	Yes	N/A	N/A	Yes	N/A	Yes
3	5.8	Yes	Yes	N/A	N/A	Yes	N/A	Yes
4	9	Yes	Yes	N/A	N/A	Yes	N/A	Yes
5	11.5	Yes	Yes	N/A	N/A	Yes	N/A	Yes

Emergency Control Valve accessible	YES	Connection hose to installation adequate		YES
Gas Tightness Test satisfactory	YES	Regulator working pressure:		37 mbar
Visual Inspection satisfactory	YES	Regulator lock up pressure:		44 mbar

DETAILS OF WORK CARRIED OUT

DETAILS OF REMEDIAL WORK REQUIRED

DETAILS OF THE CONTRACTOR			
Trading Title: Bm Plumbing Services 28 Barchester Rd Langley Postcode: SL3 7HA	Gas Safe Number: 5507552 Gas ID Number: 5507553 Telephone Number: 07904203382		
Report Issued By: Name: Ben Matthews	Signature: 	Date: 16/10/2025	
Report Received By: Name: 	Signature: 	Date: 	

THE NEXT GAS SAFETY CHECK MUST BE COMPLETED WITHIN THE NEXT 12 MONTHS OR PREFERABLY SOONER.